

International Fire Code 2012 edition

308.1.4 Open-flame cooking devices. Charcoal burners and other open-flame cooking devices shall not be operated on combustible balconies or within 10 feet (3048 mm) of combustible construction.

Exceptions:

1. One- and two-family *dwelling*s.
 2. Where buildings, balconies and decks are protected by an *automatic sprinkler system*.
 3. LP-gas cooking devices having LP-gas container with a water capacity not greater than 21/ 2 pounds [nominal 1 pound (0.454 kg) LP-gas capacity].
- 308.1.5 Location near combustibles. Open flames such as